









**DESBARATS
DRINKING WATER SYSTEM
WATERWORKS # 210001870**

**ANNUAL & SUMMARY
REPORTS 2023**

Introduction

This Annual and Summary Report has been prepared in accordance with both Schedule 22 and section 11 of Ontario Regulation 170/03. In this manner, the requirements by regulation for each report have been consolidated into a single document. This Report is intended to brief the ownership and consumers of the Desbarats Drinking Water System on the system's performance over the past calendar year January 1 to December 31, 2023.

This report encompasses all elements as required by O. Reg. 170/03. Each section explains what is required for the category Small Municipal Residential DWS (as it pertains to the Desbarats DWS) and how limits were met or if shortfalls were revealed. The last section contains a list of tables and definitions of terms identified in this report.

 System Description	Page 3
 Water Quality	Page 4
 Compliance	Page 7
 Flows	Page 7
 Report Availability	Page 9
 Tables, Definition of Terms App: A/B	Page 10

System Description

The Desbarats water treatment plant is rated as a Class 2 Water Treatment subsystem, and for the purposes of O. Reg. 170/03 it is categorized as a Small Municipal Residential system.

The treatment plant includes two (2) low lift centrifugal pumps, each pump rated at 4.24 L/s that deliver surface water from Lake Huron.

The treatment system includes an Ecodyne Monoplant complete with mechanical flocculation, sedimentation, and dual media filtration compartments. The filter portion of the package plant involves a dual media of sand and anthracite and provides for filtering to waste after backwashing. Waste from the clarifier is drained at timed intervals to backwash settling tanks from which supernatant travels by gravity to a diffuser in Lake Huron, located downstream from the intake site.

Post chlorination using sodium hypochlorite is injected after filtration before the clearwell to achieve primary and secondary chlorination. There are three (3) cells to the clearwell (reservoir) with a total storage capacity of 142 cubic meters. There is standby power for continued pumping capacity and plant operations. The system also involves six (6) pre-charged pressure tanks for distribution pressure control.

- There are approximately 276 residents using the system with 110 service connections (93 private residences) and an elementary/secondary school with a total population of about 600 students. Water is provided to the distribution system through a submarine transmission main

Chemicals

Chemicals utilized at the Desbarats Treatment plant during 2023 include:

- Sodium Hypochlorite for primary and secondary disinfection
- Aluminum Sulphate for coagulation
- Polymer (LT20) as a coagulant aid
- Soda Ash for pH and alkalinity adjustment

2023 Expenditures

During the year of 2023, expenses were incurred to maintain treatment and distribution functions:

- ESA services
- 12-month surveillance audit (SAI Global)
- Air compressor
- Floc mixer motor an coupling
- Chemical shed construction
- Transmission line repairs

2023 Drinking Water System Changes

Form 1 – Record of Watermains Authorized as a Future Alteration

- n/a

Form 2 – Record of Minor Modification or Replacements

- n/a

Form 3 – Record of addition, modification or replacement of equipment discharging a contaminant of concern to the atmosphere

- n/a

Water Quality

Microbiological Sampling and Testing

Sampling is conducted weekly for the DWS at the frequencies and locations identified by Schedule 11 of O. Reg 170/03 for Small Municipal Residential Systems.

Table 1: Microbiological sampling requirements

Location	Sample Analysis	# samples	Frequency
Raw	EC / TC	1 sample	monthly
Treated	N/A	-	-
Distribution	EC / TC/ HPC	1 sample	bi-weekly

Desbarats' raw samples are collected from a sample tap from the raw water header. Treated samples are collected from a sample tap from the treated discharge header prior to distribution. Distribution samples are rotated weekly at the following locations representing areas throughout the hamlet: Township Office, Baptist Church, Arena, and Central Algoma Secondary School. Other locations may be sampled as required.

Table 2: Microbiological Sample Results

Type	# samples	EC (range)	TC (range)	# samples	HPC (range)
Raw	12	0 - 5	6 - 146	0	-
Distribution	27	0	0	27	0

Operational Checks and Testing

Operational testing is completed as per Schedules 6 & 7 of O. Reg. 170/03 for Small Municipal Residential Systems. Checks and testing are completed on site at the water treatment facility by licensed operators. Continuous monitoring analyzers (collecting 5-minute readings) are utilized for measurement of filter turbidity and chlorine residuals.

Table 3: Monthly Filter Turbidity Results

Month	Avg turbidity (NTU)	Range (NTU)	Monthly Filter Efficiency
January	0.04	0.03 - 1.18	99.9
February	0.04	0.02 - 0.26	100
March	0.04	0.03 - 0.68	99.9
April	0.04	0.03 - 0.47	99.9
May	0.03	0.02 - 4.99	99.6
June	0.03	0.03 - 0.74	99.9
July	0.03	0.02 - 0.19	100
August	0.03	0.02 - 0.09	100
September	0.03	0.02 - 0.06	100
October	0.05	0.02 - 0.86	99.2
November	0.05	0.02 - 0.67	99.5
December	0.03	0.02 - 0.59	99.9

Desbarats maintained filter compliance each month above 95%, (required limit) to achieve necessary filtration credits for primary disinfection.

Table 4: Chlorine Residuals

Month	Average Chlorine Residual (mg/L)	Chlorine Residual Range (mg/L)
January	1.49	1.29 - 1.84
February	1.43	1.29 - 1.72
March	1.54	1.25 - 1.97
April	1.41	1.18 - 1.64
May	1.44	1.18 - 1.69
June	1.38	1.04 - 1.76
July	1.56	1.32 - 1.81
August	1.57	1.32 - 1.94
September	1.51	0.96 - 1.99
October	1.63	0.87 - 2.31
November	1.50	1.26 - 2.16
December	1.49	0.93 - 1.85

Chlorine residuals are continuously monitored, and data is recorded at 5-minute intervals.

Chemical Sampling and Testing

Schedule 13 of O. Reg. 170/03 outlines chemical sampling requirements for Small Municipal Residential systems. Schedules 23 (inorganics) and 24 (organics) are collected every 60 months as well as sodium and fluoride. This system requires quarterly sampling for Nitrites/Nitrates, THMs and HAAs. Schedule 15.1 outlines the requirements for semi-annual lead testing (2 periods per year). Desbarats’ lead sampling follows the regulation’s plumbing exemption but monitors the distribution system water quality for changes that may impact lead corrosion.

Table 5: Schedule 23 - Inorganics

Parameter	Sample Date	Result (µg/L)	Units	ODWS
Antimony	23-Jan-23	<0.5	µg/L	6
Arsenic	23-Jan-23	<1	µg/L	10
Barium	23-Jan-23	9	µg/L	1000
Boron	23-Jan-23	<2	µg/L	5000
Cadmium	23-Jan-23	<0.1	µg/L	5
Chromium	23-Jan-23	<1	µg/L	50
Fluoride	23-Jan-23	<0.05	mg/L	1.5
Mercury	23-Jan-23	<0.1	µg/L	1
Selenium	23-Jan-23	0.2	µg/L	50
Sodium	23-Jan-23	4.35	mg/L	20
Uranium	23-Jan-23	<1	µg/L	20

All results for inorganic parameters are within the maximum acceptable concentrations (MAC) of the Ontario Drinking Water Quality Standards as defined in O. Reg. 169/03. No result is above the half MAC with the exception of sodium which has an aesthetic objective (AO) of 200 mg/L but has a limit of 20 mg/L for medical reasons and would require notifications if exceeded.

Table 6: Nitrate/ Nitrite Results

Date	ODWS	4-Jan	4-Apr	4-Jul	7-Oct
Unit	mg/L	mg/L	mg/L	mg/L	mg/L
Nitrate	10	0.29	0.34	0.34	0.30
Nitrite	1.0	<0.05	<0.05	<0.05	<0.05

All quarterly results for Nitrites and Nitrates are well below ODWS.

Table 7: Disinfection By-products Results (THM/HAA)

Date	ODWS	Q1	Q2	Q3	Q4	RAA
Unit	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
THM	100	19	15.9	22.6	21.8	17.6
HAA	80	10.1	8	18	13	14.5

ODWS established a MAC of 80 for HAAs effective January 1, 2020.

Table 8: Community Lead Sampling Results

Location Type	Alkalinity, mg/L	pH
Distribution monitoring	53	7.5

Desbarats water system is eligible for plumbing exemption, however alkalinity and pH are required for analysis in the distribution every winter and summer collection periods and Lead in distribution every 3 years for the winter and summer periods.

Table 9: TSS – C of A requirement for plant process wastewater

Quarter	Result Value	Unit
Q1	5.0	mg/L
Q2	3.7	mg/L
Q3	18.6	mg/L
Q4	5.7	mg/L

The 2023 annual average suspended solids concentration is 8.1 mg/L for plant service water (backwash and instrumentation flows) released back to the environment.

Table 10: Schedule 24 - Organics

Parameter	Date	Result	Unit	ODWS
Alachlor	23-Jan-23	<0.238	µg/L	5
Atrazine + N-dealkylated metabolites	23-Jan-23	<0.5	µg/L	5
Azinphos-methyl	23-Jan-23	<0.179	µg/L	20
Benzene	23-Jan-23	<0.1	µg/L	1
Benzo(a)pyrene	23-Jan-23	<0.01	µg/L	0.01
Bromoxynil	23-Jan-23	<0.0939	µg/L	5
Carbaryl	23-Jan-23	<3	µg/L	90
Carbofuran	23-Jan-23	<4	µg/L	90
Carbon Tetrachloride	23-Jan-23	<0.2	µg/L	5
Chlorpyrifos	23-Jan-23	<0.2	µg/L	90
Diazinon	23-Jan-23	<0.179	µg/L	20
Dicamba	23-Jan-23	<0.0822	µg/L	120
1,2-Dichlorobenzene	23-Jan-23	<0.2	µg/L	200
1,4-Dichlorobenzene	23-Jan-23	<0.3	µg/L	5
1,2-Dichloroethane	23-Jan-23	<0.2	µg/L	5
1,1-Dichloroethylene (vinylidene chloride)	23-Jan-23	<0.3	µg/L	14
Dichloromethane	23-Jan-23	<1	µg/L	50
2-4 Dichlorophenol	23-Jan-23	<0.3	µg/L	900
2,4-Dichlorophenoxy acetic acid	23-Jan-23	<0.352	µg/L	100
Diclofop-methyl	23-Jan-23	<0.117	µg/L	9
Dimethoate	23-Jan-23	<0.179	µg/L	20
Diquat	23-Jan-23	<0.7	µg/L	70

Parameter	Date	Result	Unit	ODWS
Diuron	23-Jan-23	<10	µg/L	150
Glyphosate	23-Jan-23	<20	µg/L	280
Malathion	23-Jan-23	<0.179	µg/L	190
2-Methyl-4-Chlorophenoxyacetic Acid (MCPA)	23-Jan-23	<5.87	µg/L	100
Metolachlor	23 Jan-23	<0.119	µg/L	50
Metribuzin	23-Jan-23	<0.119	µg/L	80
Monochlorobenzene	23-Jan-23	<0.5	µg/L	80
Paraquat	23-Jan-23	<0.3	µg/L	10
Pentachlorophenol	23-Jan-23	<0.3	µg/L	60
Phorate	23-Jan-23	<0.119	µg/L	2
Picloram	23-Jan-23	<0.0822	µg/L	190
Polychlorinated Byphenols (PCB)	23-Jan-23	<0.06	µg/L	3
Prometryne	23-Jan-23	<0.0596	µg/L	1
Simazine	23-Jan-23	<0.179	µg/L	10
Terbufos	23-Jan-23	<0.119	µg/L	1
Tetrachloroethylene	23-Jan-23	<0.3	µg/L	10
2,3,4,6-Tetrachlorophenol	23-Jan-23	<0.2	µg/L	100
Triallate	23-Jan-23	<0.119	µg/L	230
Trichloroethylene	23-Jan-23	<0.2	µg/L	5
2,4,6-Trichlorophenol	23-Jan-23	<0.2	µg/L	5
Trifluralin	23-Jan-23	<0.119	µg/L	45
Vinyl Chloride	23-Jan-23	<0.1	µg/L	1

All results for the required organic sampling of schedule 24 are below the MAC.

Compliance

Adverse Water Quality Incidents

During 2023, the Desbarats DWS reported one incident of adverse water quality.

Table 11: Adverse Water Quality Incidents

Date	Incident Reported
23 Oct	Loss of distribution pressure (repair of transmission line)

Annual Drinking Water System Inspection

The annual DWS inspection took place on May 25, 2023, by MECP Drinking Water inspector Shelley Baggio. Zero non-compliance and four additional recommendations and best practice were identified.

The DWS received a final inspection rating of 100.0%.

Flows

The Permit to Take Water authorizes the municipality to draw water from Lake Huron at a rate not to exceed 547.2 m³/d.

The maximum daily volume taken was 239 m³/d, 43.7 % of the permit limit.

Municipal Drinking Water Licence: 275-201 specifies a maximum intake capacity of 366 m³/d.

The max flow rate reported was 175 m³/d, 47.8% of the rated capacity.

The Desbarats WTP treated and distributed a total of 43,087 m³ during the year of 2023. The average day treated flow demand was 91.5 m³/d, and maximum day flow was 175 m³/d on October 3, 2023.

Chart 1: 5-year Flow Comparison





Table 12: Raw and Treated water Flows 2023

2024	Raw Water Flows					Treated Water Flows				
Month	Raw Water (m ³)	Minimum Day (m ³ /d)	Maximum Day (m ³ /d)	Average Day (m ³ /d)	% Max. Flow Day of PTTW	Treated Water (m ³)	Minimum Day (m ³ /d)	Maximum Day (m ³ /d)	Average Day (m ³ /d)	% Max Flow Day of Rated Capacity
January	3,260	81	124	105.0	22.7	2,587	64	101	83.5	27.6
February	3,127	90	150	111.7	27.4	2,336	64	120	83.4	32.8
March	3,482	92	156	112.3	28.5	2,681	64	114	86.5	31.1
April	2,673	76	104	89.1	19.0	2,127	59	78	70.9	21.3
May	2,938	65	133	94.8	24.3	2,357	61	104	76.0	28.4
June	3,186	89	155	106.2	28.3	2,582	81	131	86.1	35.8
July	3,444	94	125	111.1	22.8	2,600	75	93	83.9	25.4
August	3,914	107	149	126.3	27.2	2,847	75	107	91.8	29.2
September	4,577	121	206	152.6	37.6	3,233	75	157	107.8	42.9
October	5,623	89	239	181.4	43.7	4,270	75	175	137.7	47.8
November	3,296	85	127	109.9	23.2	2,778	75	112	92.6	30.6
December	3,567	91	145	115.1	26.5	3,044	75	122	98.2	33.3

Chart 2: Desbarats WTP Flows 2023



Report Availability

Annual Report

Section 11 of O. Reg. 170/03 defines that this Annual Report must be given, without charge, to every person who requests a copy. Effective steps must also be taken to advise users of water from the system that copies of the report are available, without charge, and of how a copy may be obtained. This Annual Report shall be made available for inspection by the public at the Township Office.

Township of Johnson
1 Johnson Drive
Desbarats, ON
P0R 1E0

Summary Report

This Summary report for The Desbarats Drinking Water System for the period of January 1st to December 31st, 2023, has been prepared in accordance to Schedule 22 of O. Reg. 170/03.

In accordance with Schedule 22 of O. Reg. 170/03, this Summary Report has been provided to The Township of Johnson.

Tables, Definition of Terms

Appendix A: List of Tables/ Charts

Table 1:	Microbiological sampling requirements
Table 2:	Microbiological Sample Results
Table 3:	Monthly Filter Turbidity Results
Table 4:	Treated Chlorine Residuals
Table 5:	Schedule 23 - Inorganics
Table 6:	Nitrite/ Nitrate Results
Table 7:	Disinfection By-products Results (THM/HAA)
Table 8:	Community Lead Sampling Results
Table 9:	TSS – C of A requirement for plant process wastewater
Table 10:	Schedule 24 - Organics
Table 11:	Adverse Water Quality Incidents
Table 12:	Raw and Treated water Flows 2023
Chart 1:	5-year Flow Comparison
Chart 2:	Desbarats WTP Flows 2023

Appendix B: Definition of Terms

Acronym	Definition
AWQI	Adverse water quality incident
BWA	Boil Water Advisory
DM	Dual Media
DWS	Drinking water system
EC	E. Coli
HAA	Haloacetic acids
HPC	Heterotrophic plate count
MAC	Maximum Acceptable Concentration
m³	Cubic metres
m³/d	Cubic metres per day
mg/L	Milligram per litre (part per million)
ML	Megalitre (1000 m ³)
NTU	Nephelometric turbidity unit
ODWS	Ontario Drinking Water Standards
O. Reg. 170/03	Ontario Regulation 170/03
PTTW	Permit to take water
SCADA	Supervisory control and data acquisition
TC	Total coliforms
THM	Trihalomethane
µg/L	Microgram per litre (part per billion)
WD	Water distribution
WT	Water treatment
WTP	Water treatment plant